




## **E.ON's Activities on IGCC and Zero Emissions Plant**

Robin Irons - Technical Head, Zero Emission Plant

Rugeley - 20 June 2007

## The Need for New Capacity

- By 2015 the UK will see up to 26GW of plant closures (LCPD and nuclear life expiry)
- With no new build, demand may exceed supply in winter peaks by about 2011



- Estimated 36 GW of new capacity needed by 2020 ~ 45% of UK capacity


Replacement with gas-fired CCGTs will not reduce overall CO2 emissions – and lead to ~70% gas dependency.

# Replacement Generation Options

## **Considerations include:**


- Government Policy (including post-Kyoto position, Security of Supply)  
– the Energy White Paper, EC Policy Initiatives, G8 .....
- Environmental Performance
- Commercial Viability (including cost of fuel and carbon)
- Public Acceptability (a factor for new nuclear?)
- Technology maturity (clean coal technologies, marine?)
- Reliability (e.g. the intermittency of wind)
- Extent of Deployment (can enough be built in time; e.g small scale CHP, nuclear consenting)

# CO<sub>2</sub> abatement from coal – twin track approach



Source: IEA

# CO2 Capture Options




# **GASIFICATION WITH CAPTURE**

# IGCC with CO<sub>2</sub> Capture

## Current Position

- Killingholme
- Essence of the \$1B US FutureGen project
- EU Hypogen/Dynamis project has similar goal



## E.ON UK's CCS project at Killingholme

### Overview



- Killingholme will nominally be a 450MW IGCC+CCS fuelled on coal
- Built on or close to the existing Killingholme site
- Multiple CO<sub>2</sub> storage options identified in the Southern North Sea (SNS)



Killingholme could be operational by late 2011




The existing E.ON site is the front running site on which to build Killingholme IGCC



## Multiple CO<sub>2</sub> storage sites identified in the SNS


- Killingholme is well positioned for CO<sub>2</sub> evacuation from Easington and Theddlethorpe
- The vast majority of gas fields in the SNS are capable of storing CO<sub>2</sub>
- The SNS is capable of storing 2.8BT of CO<sub>2</sub>, Killingholme will produce 3MT of CO<sub>2</sub> pa.



Killingholme could be operational by 2011


### Milestones

- Sept 2006 Feasibility study reports
- Jan 2007 – July 2007 Pre-FEED study
- Aug 2007 – May 2008 Full FEED study
- June 2008 Investment decision
- July 2008– Sept 2011 Construction
- Dec 2011 Plant commissioning




This timetable is ambitious but is designed to ensure E.ON remains front-running utility on coal based carbon capture. Clearly there are factors that could cause delay

# OXYFUEL







## Oxygen tank and evaporator



## Carrier stream – ground floor





## Civil works for bulk stream tower




Reduction in net flow


Operation: changeover

Emissions ( $\text{CO}_2$ , NO,  $\text{SO}_2$ , CO) and C  
burnout


Combustion stability





1. Warm up on gasoil, then switchover to coal for air baseline test
2. Revert to gasoil during switchover of carrier stream
3. Revert to coal for full switchover (bulk)




CO <sub>2</sub> [%vol,dry]	Gasoil, air = 14	Coal, air = 17	Coal, oxyfuel = 80
Changeover and CO <sub>2</sub> concentration response time < 10 minutes			











~75% reduction in exhaust gas requiring treatment

~80% CO<sub>2</sub> content in dry exhaust gas

Reduction in NO concentration

Increase in CO, SO<sub>2</sub> concentration

Reduction in absolute levels of all emissions

Burnout degraded at low O<sub>2</sub> enrichment

Flame stability degraded

Reduced flame and gas temperatures

Increasing O<sub>2</sub> enrichment = closer to air

>50 hours of operation in full oxyfuel mode

Improved stability during operation

Flame detection issues resolved

One man operation


Optimised controller response parameters

Recalibration of instruments

Fuel feed arrangements – difficult coal

>80% (dry) CO<sub>2</sub> concentration

Proof of trips and interlocks



O<sub>2</sub> enrichment – higher levels, enrichment of primary

Heat transfer

Fuel feeding and conveying

Flame detection

Tramp air ingress

Ash behaviour/fate of trace elements

Fouling behaviour

Corrosion

Oxyfuel combustion achievable

Staged combustion can reduce NO emissions, if required

Combustion efficiency similar to air can be achieved

Optimum O<sub>2</sub> enrichment likely to result in lower volume flow than air

SO<sub>2</sub> (and others?) concentrated by ~4 times

Attention needs to be paid to control and instrumentation

Scope for increased enrichment (>26%) without exceeding materials constraints, whilst reducing shaft work

Safety and efficiency improvements possible in milling